





+385 (0)1 33 62 513



Declaration of conformity

No.1414

Manufacturer	KLIMAOPREMA d.d.	
	Gradna 78A, 10430 Samobor, Croatia	
Person authorized to compile	Siniša Murtezanović, mag.eng.mech.	
technical documentation	Chief technical officer	
Product description	General product name:	air terminal device
	Product type:	round ventilation damper
	Product model:	RD
	Product use:	regulation of airflow in ventilation systems

We declare under our own responsibility that described products meets the characteristics and properties and is in accordance with the data described in the technical documentation. Technical documentation for the listed product is available on our website: www.klimaoprema.com.

We hereby declare that the described product meets the requirements of the following standards:

HRN EN 1751:2014	Ventilation for buildings Air terminal devices Aerodynamic testing of damper and valves
------------------	---

Reaction to fire, resistance to fire:

Product is made of galvanised steel and is considered to be reaction to fire Class A1, in accordance with Commision Decision 1996/603/EC and Commision Decision 2000/605/EC.

Emissions of dangerous substances:

Product does not contains harmful substances to human and environment.

The product is produced and controlled in accordance with an integrated management system that includes the standards:

ISO	9001:2015	TÜV NORD No. 44 100 20430031 from 17.03.2020.
ISO 1	14001:2015	TÜV NORD No. 44 104 20430031 from 17.03.2020.
ISO 4	15001:2018	TÜV NORD No. 44 126 20430031 from 17.03.2020.

Technical documentation reference number: TM 1414.

EU Declaration of conformity according to the valid EU Directives is not allowed because there are no harmonised standards for the product.

Signed for the manufacturer on his behalf:

Sergio Galošić, CEO

2 Klima pirema d.d. Za projektiranje, proizvodnju, postavljanje, popravak i održavanje opreme za klimatizaciju 10430 SAMOBOR, GRADNA 78/A

9=5

Samobor, 17.03.2020.