

Declaration of performance

DoP No. 1715/2020



Identification code	FSD – Smoke control damper	
Intended use	To be used in conjunction with pressure differential systems and smoke and heat control systems	
Manufacturer	KLIMAOPREMA d.d. Gradna 78A, 10430 Samobor, Croatia	
System of assessment and verification of constancy of performance	System 1	
Harmonised standard	EN 12101-8:2011	
Notified body	FIRES, Slovakia, Notified body 1396–Certificate of constancy of performance 1396-CPR-0180	
Declared performance	Essential characteristics	Performance/Class
	Nominal activation conditions/sensitivity	Pass
	Response delay (response time):	Pass (AA)
	Operational reliability:	C10000 (with load)
	Fire resistance: - integrity E insulation I - smoke leakage S - mechanical stability (under E) - maintenance of cross-section (under E) - high operational temperature	EI 90(_{vew, i ↔ o}) S 1500 C10000AAmulti
	Durability: - of response delay - of operational reliability	Pass (AA) Pass (C10000)
	Leak tightness class of the casing: - according to EN 1751	Class ≥ C
	Leak tightness class of the casing: - according to EN 1751	Class ≥ 2

This Declaration of performance is provided on: www.klimaoprema.com.


Declaration of performance of the described product is in conformity with declared performance. This Declaration of performance is issued in accordance with the Regulation (EU) No. 305/2011, Delegated Regulation (EU) No. 574/2014, Delegated Regulation (EU) No. 568/2014, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer by:

Sergio Galošić, CEO

2 klimaoprema d.d.
Za projektiranje, proizvodnju, postavljanje,
popravak i održavanje opreme za klimatizaciju
10430 SAMOBOR, GRADNA 78/A

Samobor, 28.07.2020.



For achievement of the declared performance, this product has to be used according to the specifications and technical instructions of the manufacturer!